



Mason School District

School Administrative Unit #89
13 Darling Hill Rd. Mason, NH 03048
(603) 878-2962 (603) 878-3439 (fax)

June 13, 2023

Dear Parents and Guardians,

We are writing to let you know that Mason Elementary School recently completed testing for lead in drinking water. This is part of an ongoing effort related to New Hampshire's House Bill 1421, which requires school and child care facilities to test for lead in drinking water and to act when lead is found at levels at or above 5 parts per billion (ppb).

Lead is a toxic heavy metal that has a range of adverse health effects if inhaled or swallowed. Lead rarely occurs naturally in New Hampshire's drinking water sources (groundwater or surface water) and typically enters drinking water due to the wearing away of piping, faucets, fixtures and other plumbing materials.

Because lead is tasteless, odorless and colorless in drinking water, testing is the only way to learn whether lead is present. It is important to sample each faucet or water fountain that is used for drinking or food prep because test results can vary between locations.

During recent testing, we collected samples from 16 drinking water outlets (e.g., drinking fountains, classroom faucets, kitchen sinks), with 3 samples testing at or above 5 ppb, the level where action must be taken.

We have removed access to these outlets until the problem can be corrected. The table below shows a list of all of the tested outlets, their locations, sample results and our planned remediation.

Location	Sample Result (ppb)	Planned Remediation
Kitchen Dish Room	9.86	Replace faucet and retest
Kitchen Prep Sink	7.88	Replace faucet and retest
Kindergarten Adult Sink	5.21	Replace faucet and retest

The 3 sinks mentioned above that tested high are not sinks that we typically use for drinking or food prep. All sample results and additional resources from the New Hampshire Department of Environmental Services (NHDES) can be viewed at gettheleadoutnh.org.

Sincerely,

Christopher Rush – Facilities Manager

Kristen Kivela
Superintendent/Principal
kkivela@sau89.org

Patricia O'Mara
Director of Student Services
pomara@sau89.org

Brenda Wiley
Accounts Payable
bwiley@sau89.org